

## **GENERAL SPECIFICATIONS**

**UGS** 

## 1. General Agreement

1.1 The master agreement entered into between the contractor and the Department shall form the basis for all work performed; and the specifications, requirements and conditions described herein are in addition thereto and shall also be a part of the basis for all work performed and shall apply in the manner set forth herein unless otherwise modified or described in the working drawings or in the agreement for a specific installation.

## 2. Working Drawings

- 2.1 Each working drawing will indicate the structures and facilities to be installed both by type and quantity. Charges to the Department for work performed shall be subject to adjustment, as agreed upon in each instance between the contractor and an authorized representative of the Department whenever modification is made in either the type or quantity of such structures or facilities.
- 2.2 Each working drawing will also indicate the preferred location of structures and facilities to be installed. Deviations in such preferred locations may be made as agreed upon between the contractor and an authorized representative of the Department. Adjustments in charges to the Department based upon such deviations shall be limited to those for changes in type and quantity of structures and facilities as set forth in 2.1 above, provided, however, that this restriction shall not apply to deviations made solely for the convenience of the Department.
- 2.3 Each working drawing will also indicate, to the extent known by the Department, the approximate plan of obstructions in the vicinity. It shall be the contractor's responsibility solely and entirely to determine the actual location of all obstructions, whether known to the Department or not by means of test holes and otherwise as may be necessary or advisable.

## 3. Structures and Accessories

- 3.1 Each structure or facility installed shall be in accordance with and shall include accessories and meet other requirements as set forth in the reference page listed below. The current revision, as of date or working drawing, of each structure drawing, accessory drawing or other reference drawing is the only one applicable: use of a previously issued drawing is contingent upon such drawing still being the current revision.
- 3.2 Each vault shall be in conformance with requirements, given in UGS-005.
- 3.3 Each manhole shall be in conformance with requirements given in UGS-006.
- 3.4 Each pull box shall be in conformance with requirements given in UGS-007.
- 3.5 Each electric service box shall be in conformance with requirements given in UGS-009.
- 3.6 Each slab-box shall be in conformance with requirements given in UGS-010.
- 3.7 Each duct bank and each duct terminal shall be in conformance with requirements given in UGS-008.

Issued: 12/03 Rev: 1

UNDERGROUND STRUCTURES
STANDARDS